



产品认证证书

证书编号: CQC16003150133

申请人名称及地址

I. L. M. E. SpA

Via Marco Antonio Colonna, 9 20149 Milan (MI) - Italy (意大利)

制造商名称及地址

I. L. M. E. SpA

Via Marco Antonio Colonna, 9 20149 Milan (MI) - Italy (意大利)

生产企业名称及地址

I. L. M. E. SpA (V025413)

Via Bovisasca, 30-20026 Novate Milanese (MI) - Italy (意大利)

产品名称和系列、规格、型号

电连接器

见附件

产品标准和技术要求

CQC1101-2011

认证模式

产品型式试验+初次工厂检查+获证后监督

上述产品符合CQC11-462222-2011认证规则的要求, 特发此证。

发证日期: 2017年02月14日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2016年08月01日

主任: _____



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C 0094842



PRODUCT CERTIFICATE

No.: CQC16003150133

NAME AND ADDRESS OF THE APPLICANT

I.L.M.E.SpA
Via Marco Antonio Colonna,9 20149 Milan(MI)-Italy

NAME AND ADDRESS OF THE MANUFACTURER

I.L.M.E.SpA
Via Marco Antonio Colonna,9 20149 Milan(MI)-Italy

NAME AND ADDRESS OF THE FACTORY

I.L.M.E.SpA (V025413)
Via Bovisasca,30-20026 Novate Milanese (MI)-Italy

NAME, MODEL AND SPECIFICATION

Electrical Connectors
See Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

CQC1101-2011

CERTIFICATION MODEL

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned products have met the requirements of certification rules CQC11-462222-2011.

Date of issue: Feb.14,2017

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Aug.01,2016

President:


Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>



产品认证证书

附录:

第 1 页 共 2 页

证书编号: CQC16003150133

纸号: 94842

产品名称(中文):

电连接器

规格和型号:

CKS 04 10A 400V 6kV; CKS 03 10A 400V 6kV 3; CKS 03 RY 10A 400V 6kV 3;
CKS 04 RY 10A 400V 6kV 3; JCKS 03 10A 400V 6kV 3; JCKS 04 10A 400V 6kV 3;
JKS 03 10A 400V 6kV 3; JKS 04 10A 400V 6kV 3; CQ 12 10A 400V 6kV 3;
CX 01 J 10A 400V 6kV 3; CX 02 J 10A 400V 6kV 3; CX 01 B 10A 50Vac/120Vdc 0.8kV 3;
CX 17 D 10A 160V 2.5kV 3; CD 64 10A 250V 4kV 3; CD 08 10A 50Vac/120Vdc 0.8kV 3;
CD 40 10A 250V 4kV 3; CD 07 10A 250V 4kV 3; CD 07 N 10A 250V 4kV 3;
CD 15 10A 250V 4kV 3; CD 25 10A 250V 4kV 3; CD 25 Z 10A 250V 4kV 3;
CDD 24 10A 250V 4kV 2; CDD 38 10A 250V 4kV 2; CDD 42 10A 250V 4kV 2;
CDD 72 10A 250V 4kV 2; CDD 72 N 10A 250V 4kV 2; CDD 108 10A 250V 4kV 2;
CDD 108 N 10A 250V 4kV 2; CK 03 10A 230/400V 4kV 3; CK 04 10A 230/400V 4kV 3;
CK 03 RY 10A 230/400V 4kV 3; CK 04 RY 10A 230/400V 4kV 3; JCK 03 10A 230/400V 4kV 3;
JCK 04 10A 230/400V 4kV 3; JK 03 10A 230/400V 4kV 3; JK 04 10A 230/400V 4kV 3;
CT 40 L 10A 250V 4kV 3; CT 40 R 10A 250V 4kV 3; CT 64 L 10A 250V 4kV 3;
CT 64 R 10A 250V 4kV 3; CTS 40 L 10A 250V 4kV 3; CTS 40 R 10A 250V 4kV 3;
CTS 64 L 10A 250V 4kV 3; CTS 64 R 10A 250V 4kV 3; CX 12 D 10A 250V 4kV 2;
CX 02 B 10A 50Vac/120Vdc 0.8kV 3; CX 04 B 10A 50Vac/120Vdc 0.8kV 3
CDS 09 10A 400V 6kV 3; CDS 18 10A 400V 6kV 3; CDS 27 10A 400V 6kV 3;
CDS 27 N 10A 400V 6kV 3; CDS 42 10A 400V 6kV 3; CDS 42 N 10A 400V 6kV 3;

注: 此附录与证书同时使用时有效。

主任: _____



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>



产品认证证书

附录:

第 2 页 共 2 页

证书编号: CQC16003150133

纸号: 94842

JDS 09 10A 400V 6kV 3; JDS 18 10A 400V 6kV 3; JDS 27 10A 400V 6kV 3;

JDS 27 N 10A 400V 6kV 3; JDS 42 10A 400V 6kV 3; JDS 42 N 10A 400V 6kV 3

无分断能力 固定连接器 I 类 不带联锁 螺纹端子连接 -40T125 污染等级3 无负载500
次操作循环 灼热丝850℃ 球压125℃ 针焰10s PTI175

注: 此附录与证书同时使用时有效。

主任: _____



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



产品认证证书

证书编号: CQC16003150187

申请人名称及地址

I. L. M. E. SpA

Via Marco Antonio Colonna, 9 20149 Milan (MI) - Italy (意大利)

制造商名称及地址

I. L. M. E. SpA

Via Marco Antonio Colonna, 9 20149 Milan (MI) - Italy (意大利)

生产企业名称及地址

I. L. M. E. SpA (V025413)

Via Bovisasca, 30-20026 Novate Milanese (MI) - Italy (意大利)

产品名称和系列、规格、型号

电连接器

见附件

产品标准和技术要求

CQC1101-2011

认证模式

产品型式试验+初次工厂检查+获证后监督

上述产品符合CQC11-462222-2011认证规则的要求, 特发此证。

发证日期: 2017年02月14日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2016年08月02日

主任: _____



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C 0094843



PRODUCT CERTIFICATE

No.: CQC16003150187

NAME AND ADDRESS OF THE APPLICANT

I.L.M.E.SpA
Via Marco Antonio Colonna,9 20149 Milan(MI)-Italy

NAME AND ADDRESS OF THE MANUFACTURER

I.L.M.E.SpA
Via Marco Antonio Colonna,9 20149 Milan(MI)-Italy

NAME AND ADDRESS OF THE FACTORY

I.L.M.E.SpA (V025413)
Via Bovisasca,30-20026 Novate Milanese (MI)-Italy

NAME, MODEL AND SPECIFICATION

Electrical Connectors
See Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

CQC1101-2011

CERTIFICATION MODEL

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned products have met the requirements of certification rules
CQC11-462222-2011.

Date of issue: Feb.14,2017

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing
certification body until the expiry date.

Date of original certification: Aug.02,2016

President:


Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0094843



产品认证证书

附录:

第 1 页 共 3 页

证书编号: CQC16003150187

纸号: 94843

产品名称 (中文):

电连接器

规格和型号:

CSH 24 16A 500V 6kV 3; CSH 06 16A 500V 6kV 3; CSH 10 16A 500V 6kV 3;
CSH 16 16A 500V 6kV 3; CSH 16 N 16A 500V 6kV 3; CSH 24 N 16A 500V 6kV 3;
JCSE 06 16A 500V 6kV 3; JCSE 10 16A 500V 6kV 3; JCSE 16 16A 500V 6kV 3;
JCSE 16 N 16A 500V 6kV 3; JCSE 24 16A 500V 6kV 3; JCSE 24 N 16A 500V 6kV 3;
JSE 06 16A 500V 6kV 3; JSE 10 16A 500V 6kV 3; JSE 16 16A 500V 6kV 3;
JSE 16 N 16A 500V 6kV 3; JSE 24 16A 500V 6kV 3; JSE 24 N 16A 500V 6kV 3;
CX 20 C 16A 400V 6kV 3; CX 60 C 16A 400V 6kV 3; CX 01 BC 16A 50V 0.8kV 3;
JCNE 06 16A 500V 6kV 3; JCNE 10 16A 500V 6kV 3; JCNE 16 16A 500V 6kV 3;
JCNE 16 N 16A 500V 6kV 3; JCNE 24 16A 500V 6kV 3; JCNE 24 N 16A 500V 6kV 3;
JNE 06 16A 500V 6kV 3; JNE 10 16A 500V 6kV 3; JNE 16 16A 500V 6kV 3;
JNE 16 N 16A 500V 6kV 3; JNE 24 16A 500V 6kV 3; JNE 24 N 16A 500V 6kV 3;
CX 08 C 16A 400V 6kV 3; CQE 46 16A 500V 6kV 3; CQE 10 16A 500V 6kV 3;
CQE 18 16A 500V 6kV 3; CQE 32 16A 500V 6kV 3; CQE 32 N 16A 500V 6kV 3;
CQE 46 N 16A 500V 6kV 3; CSE 06 16A 500V 6kV 3; CSE 06 RY 16A 500V 6kV 3;
CSE10 16A 500V 6kV 3; CSE 10 RY 16A 500V 6kV 3; CSE16 16A 500V 6kV 3;
CSE 16 RY 16A 500V 6kV 3; CSE 24 16A 500V 6kV 3; CSE 24 RY 16A 500V 6kV 3;
CSE16 N 16A 500V 6kV 3; CSE 16 RYN 16A 500V 6kV 3; CSE 24 N 16A 500V 6kV 3;
CSE 24 RYN 16A 500V 6kV 3; CSS 06 16A 500V 6kV 3; CSS 10 16A 500V 6kV 3;

注: 此附录与证书同时使用时有效。

主任: _____



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>



产品认证证书

附录:

第 2 页 共 3 页

证书编号: CQC16003150187

纸号: 94843

CSS 16 16A 500V 6kV 3; CSS 24 16A 500V 6kV 3; CSS 16 N 16A 500V 6kV 3;
CSS 24 N 16A 500V 6kV 3; CNE 06 T 16A 500V 6kV 3; CNE 06 TX 16A 500V 6kV 3;
CNE 06 RY 16A 500V 6kV 3; CCE 06 16A 500V 6kV 3; CNE 10 T 16A 500V 6kV 3;
CNE 10 TX 16A 500V 6kV 3; CNE 10 RY 16A 500V 6kV 3; CCE 10 16A 500V 6kV 3;
CNE 16 T 16A 500V 6kV 3; CNE 16 TX 16A 500V 6kV 3; CNE 16 RY 16A 500V 6kV 3;
CCE 16 16A 500V 6kV 3; CNE 24 T 16A 500V 6kV 3; CNE 24 TX 16A 500V 6kV 3;
CNE 24 RY 16A 500V 6kV 3; CCE 24 16A 500V 6kV 3; CNE 16 TN 16A 500V 6kV 3;
CNE 16 TXN 16A 500V 6kV 3; CNE 16 RYN 16A 500V 6kV 3; CCE 16 N 16A 500V 6kV 3;
CNE 24 TN 16A 500V 6kV 3; CNE 24 TXN 16A 500V 6kV 3; CNE 24 RYN 16A 500V 6kV 3;
CCE 24 N 16A 500V 6kV 3; CQ 05 16A 230/400V 4kV 3; CQ 08 16A 500V 6kV 3;
CDA 10 16A 250V 4kV 3; CDA 10 X 16A 250V 4kV 3; JDA 10 16A 250V 4kV 3;
CDC 10 16A 250V 4kV 3; CDA 16 16A 250V 4kV 3; CDA 16 X 16A 250V 4kV 3;
JDA 16 16A 250V 4kV 3; CDC 16 16A 250V 4kV 3; CDA 16 N 16A 250V 4kV 3;
CDA 16 XN 16A 250V 4kV 3; JDA 16 N 16A 250V 4kV 3; CDC 16 N 16A 250V 4kV 3;
CMSE 03 16A 830V 8kV 3; CME 03 T 16A 830V 8kV 3; CME 03 TX 16A 830V 8kV 3;
CMCE 03 16A 830V 8kV 3; CMSE 06 16A 830V 8kV 3; CME 06 T 16A 830V 8kV 3;
CME 06 TX 16A 830V 8kV 3; CMCE 06 16A 830V 8kV 3; CME 10 T 16A 830V 8kV 3;
CME 10 TX 16A 830V 8kV 3; CMCE 10 16A 830V 8kV 3; CMSE 06 N 16A 830V 8kV 3;
CME 06 TN 16A 830V 8kV 3; CME 06 TXN 16A 830V 8kV 3; CMCE 06 N 16A 830V 8kV 3;
CME 16 16A 400/690V 6kV 3; CMCE 16 16A 400/690V 6kV 3; CMSE 10 16A 830V 8kV 3;
CMSE 10 N 16A 830V 8kV 3; CMCE 10 N 16A 830V 8kV 3; CME 16 N 16A 400/690V 6kV 3;
CMCE 16 N 16A 400/690V 6kV 3; CT 06 L 16A 400V 4kV 2; CT 06 R 16A 400V 4kV 2;
CTSE 06 L 16A 500V 6kV 3; CTSE 06 R 16A 500V 6kV 3; CT 10 L 16A 400V 4kV 2 ;

注: 此附录与证书同时使用时有效。

主任: _____



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>



产品认证证书

附录:

第 3 页 共 3 页

证书编号: CQC16003150187

纸号: 94843

CT 10 R 16A 400V 4kV 2 ; CTSE 10 L 16A 500V 6kV 3; CTSE 10 R 16A 500V 6kV 3;
CX 05 S 16A 400V 6kV 3; CT 16 L 16A 400V 4kV 2 ; CT 16 R 16A 400V 4kV 2 ;
CTSE 16 L 16A 500V 6kV 3; CTSE 16 R 16A 500V 6kV 3; CT 24 L 16A 400V 4kV 2 ;
CT 24 R 16A 400V 4kV 2 ; CTSE 24 L 16A 500V 6kV 3; CTSE 24 R 16A 500V 6kV 3;
CX 06 C 16A 500V 6kV 3; CX 8/24 16A 230/400V 4kV 3 / 10A 160V 2,5kV 3
CME 10 TN 16A 830V 8kV 3 / 16A 500V 6kV 3;
CME 10 TXN 16A 830V 8kV 3 / 16A 500V 6kV 3;
CQEE 40 16A 500V 6kV 3;
CQEE 40 N 16A 500V 6kV 3;
CQEE 64 16A 500V 6kV 3;
CQEE 64 N 16A 500V 6kV 3;
JSH 06 16A 500V 6kV 3;
JSH 10 16A 500V 6kV 3;
JSH 16 16A 500V 6kV 3;
JSH 16 N 16A 500V 6kV 3;
JSH 24 16A 500V 6kV 3;
JSH 24 N 16A 500V 6kV 3

无分断能力 固定连接器 I 类 不带联锁 螺纹端子连接 -40T125 无负载500 次操作循环 灼热丝
850℃ 球压125℃ 针焰10s PTI175

注: 此附录与证书同时使用时有效。

主任: _____

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





产品认证证书

证书编号: CQC16003149522

申请人名称及地址

I. L. M. E. SpA

Via Marco Antonio Colonna, 9 20149 Milan (MI) - Italy (意大利)

制造商名称及地址

I. L. M. E. SpA

Via Marco Antonio Colonna, 9 20149 Milan (MI) - Italy (意大利)

生产企业名称及地址

I. L. M. E. SpA (V025413)

Via Bovisasca, 30-20026 Novate Milanese (MI) - Italy (意大利)

产品名称和系列、规格、型号

电连接器

CP 06 35A 400/690V 6kV, CP 06 N 35A 400/690V 6kV, 无分断能力 固定连接器 I 类 不带联锁 螺纹端子连接 -40T125 污染等级 3 无负载500 次操作循环 灼热丝 850℃ 球压125℃ 针焰10s PT1175

产品标准和技术要求

CQC1101-2011

认证模式

产品型式试验+初次工厂检查+获证后监督

上述产品符合CQC11-462222-2011认证规则的要求, 特发此证。

发证日期: 2016年07月26日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

主任: _____



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

C 0086043



PRODUCT CERTIFICATE

No.: CQC16003149522

NAME AND ADDRESS OF THE APPLICANT

I.L.M.E.SpA
Via Marco Antonio Colonna,9 20149 Milan(MI)-Italy

NAME AND ADDRESS OF THE MANUFACTURER

I.L.M.E.SpA
Via Marco Antonio Colonna,9 20149 Milan(MI)-Italy

NAME AND ADDRESS OF THE FACTORY

I.L.M.E.SpA (V025413)
Via Bovisasca,30-20026 Novate Milanese (MI)-Italy

NAME, MODEL AND SPECIFICATION

Electrical Connectors

CP 06 35A 400/690V 6kV、CP 06 N 35A 400/690V 6kV、无分断能力 固定连接器 I 类 不带联锁 螺纹端子连接 -40T125
污染等级3 无负载500 次操作循环 灼热丝 850℃ 球压125℃ 针焰10s PTI175

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

CQC1101-2011

CERTIFICATION MODEL

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned products have met the requirements of certification rules
CQC11-462222-2011.

Date of issue: Jul.26,2016

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing
certification body until the expiry date.

President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>



产品认证证书

证书编号: CQC16003149515

申请人名称及地址

I. L. M. E. SpA

Via Marco Antonio Colonna, 9 20149 Milan (MI) - Italy (意大利)

制造商名称及地址

I. L. M. E. SpA

Via Marco Antonio Colonna, 9 20149 Milan (MI) - Italy (意大利)

生产企业名称及地址

I. L. M. E. SpA (V025413)

Via Bovisasca, 30 20026 Novate Milanese, Milan (MI) - Italy (意大利)

产品名称和系列、规格、型号

电连接器

CX 02 4A 40A 1000V 8kV, CX 12/2 40A 690V 8kV/10A 250V 4kV, CX 02 4B 40A 1000V 8kV, CX 3/4 XD 40A 830V 8kV/ 10A 830V 8kV, CQ 04/2 40A 400/690V 6kV/ 10A 250V 4kV, CX 6/36 40A 690V 8kV/ 10A 250V 4kV, CX 03 4 40A 400/690V 6kV, CX 04 X 40A 690V 8kV, CX 03 4B 40A 500V 6kV 无分断能力 固定连接器
I 类 不带联锁 压接连接 -40T125 污染等级3 无负载500 次操作循环 灼热丝850℃ 球压125℃ 针焰10s
PTI175

产品标准和技术要求

CQC1101-2011

认证模式

产品型式试验+初次工厂检查+获证后监督

上述产品符合CQC11-462222-2011认证规则的要求, 特发此证。

发证日期: 2017年02月14日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2016年07月26日

主任: _____



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C 0094864



PRODUCT CERTIFICATE

No.: CQC16003149515

NAME AND ADDRESS OF THE APPLICANT

I.L.M.E.SpA
Via Marco Antonio Colonna,9 20149 Milan(MI)-Italy

NAME AND ADDRESS OF THE MANUFACTURER

I.L.M.E.SpA
Via Marco Antonio Colonna,9 20149 Milan(MI)-Italy

NAME AND ADDRESS OF THE FACTORY

I.L.M.E.SpA (V025413)
Via Bovisasca,30 20026 Novate Milanese,Milan(MI)-Italy

NAME, MODEL AND SPECIFICATION

Electrical Connectors

CX 02 4A 40A 1000V 8kV、CX 12/2 40A 690V 8kV/10A 250V 4kV、CX 02 4B 40A 1000V 8kV、CX 3/4 XD 40A 830V 8kV/ 10A 830V 8kV、CQ 04/2 40A 400/690V 6kV/ 10A 250V 4kV、CX 6/36 40A 690V 8kV/ 10A 250V 4kV、CX 03 4 40A 400/690V 6kV、CX 04 X 40A 690V 8kV、CX 03 4B 40A 500V 6kV 无分断能力 固定连接器 I 类 不带联锁 压接连接 - 40T125 污染等级3 无负载500 次操作循环 灼热丝850℃ 球压125℃ 针焰10s PTI175

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

CQC1101-2011

CERTIFICATION MODEL

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned products have met the requirements of certification rules CQC11-462222-2011.

Date of issue: Feb.14,2017

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Jul.26,2016

President:


Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0094864



产品认证证书

证书编号: CQC16003150132

申请人名称及地址

I. L. M. E. SpA
Via Marco Antonio Colonna, 9 20149 Milan (MI) - Italy (意大利)

制造商名称及地址

I. L. M. E. SpA
Via Marco Antonio Colonna, 9 20149 Milan (MI) - Italy (意大利)

生产企业名称及地址

I. L. M. E. SpA (V025413)
Via Bovisasca, 30-20026 Novate Milanese (MI) - Italy (意大利)

产品名称和系列、规格、型号

电连接器

CX 02 7M+CX 02 7F 70A 1000V 8kV 无分断能力 固定连接器 II 类 不带联锁 压接连接 -40T125 污染等级3 无负载500 次操作循环 灼热丝 850℃ 球压125℃ 针焰10s PTI175

产品标准和技术要求

CQC1101-2011

认证模式

产品型式试验+初次工厂检查+获证后监督

上述产品符合CQC11-462222-2011认证规则的要求, 特发此证。

发证日期: 2016年08月01日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

主任: _____



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C 0086786



PRODUCT CERTIFICATE

No.: CQC16003150132

NAME AND ADDRESS OF THE APPLICANT

I.L.M.E.SpA
Via Marco Antonio Colonna,9 20149 Milan(MI)-Italy

NAME AND ADDRESS OF THE MANUFACTURER

I.L.M.E.SpA
Via Marco Antonio Colonna,9 20149 Milan(MI)-Italy

NAME AND ADDRESS OF THE FACTORY

I.L.M.E.SpA (V025413)
Via Bovisasca,30-20026 Novate Milanese (MI)-Italy

NAME, MODEL AND SPECIFICATION

Electrical Connectors

CX 02 7M+CX 02 7F 70A 1000V 8kV 无分断能力 固定连接器 II 类 不带联锁 压接连接 -40T125 污染等级3 无负载500
次操作循环 灼热丝 850℃ 球压125℃ 针焰10s PTI175

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

CQC1101-2011

CERTIFICATION MODEL

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned products have met the requirements of certification rules
CQC11-462222-2011.

Date of issue: Aug.01,2016

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing
certification body until the expiry date.

President:


Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0086786



产品认证证书

证书编号: CQC16003149516

申请人名称及地址

I. L. M. E. SpA
Via Marco Antonio Colonna, 9 20149 Milan (MI) - Italy (意大利)

制造商名称及地址

I. L. M. E. SpA
Via Marco Antonio Colonna, 9 20149 Milan (MI) - Italy (意大利)

生产企业名称及地址

I. L. M. E. SpA (V025413)
Via Bovisasca, 30 20026 Novate Milanese, Milan (MI) - Italy (意大利)

产品名称和系列、规格、型号

电连接器

CX 4/8 80A 400V 6kV / 16A 400V 4kV, CX 4/0 80A 690V 8kV, CX 4/2 80A 690V 8kV / 16A 400V 6kV, 无分断能力 固定连接器
I 类 不带联锁 螺纹端子连接 -40T125 污染等级3 无负载500 次操作循环 灼热丝 850℃ 球压125℃ 针焰10s PTI175

产品标准和技术要求

CQC1101-2011

认证模式

产品型式试验+初次工厂检查+获证后监督

上述产品符合CQC11-462222-2011认证规则的要求, 特发此证。

发证日期: 2016年07月26日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

主任:



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C 0086047



PRODUCT CERTIFICATE

No.: CQC16003149516

NAME AND ADDRESS OF THE APPLICANT

I.L.M.E.SpA
Via Marco Antonio Colonna,9 20149 Milan(MI)-Italy

NAME AND ADDRESS OF THE MANUFACTURER

I.L.M.E.SpA
Via Marco Antonio Colonna,9 20149 Milan(MI)-Italy

NAME AND ADDRESS OF THE FACTORY

I.L.M.E.SpA (V025413)
Via Bovisasca,30 20026 Novate Milanese,Milan(MI)-Italy

NAME, MODEL AND SPECIFICATION

Electrical Connectors

CX 4/8 80A 400V 6kV / 16A 400V 4kV、CX 4/0 80A 690V 8kV、CX 4/2 80A 690V 8kV / 16A 400V 6kV、无分断能力 固定连接器 I 类 不带联锁 螺纹端子连接 -40T125 污染等级3 无负载500 次操作循环 灼热丝 850℃ 球压125℃ 针焰10s PTI175

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

CQC1101-2011

CERTIFICATION MODEL

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned products have met the requirements of certification rules CQC11-46222-2011.

Date of issue: Jul.26,2016

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

President:


Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0086047



产品认证证书

证书编号: CQC16003149379

申请人名称及地址

I. L. M. E. SpA

Via Marco Antonio Colonna, 9 20149 Milan (MI) - Italy (意大利)

制造商名称及地址

I. L. M. E. SpA

Via Marco Antonio Colonna, 9 20149 Milan (MI) - Italy (意大利)

生产企业名称及地址

I. L. M. E. SpA (V025413)

Via Bovisasca, 30-20026 Novate Milanese (MI) - Italy (意大利)

产品名称和系列、规格、型号

电连接器

CX 02 G 100A 1000V 8kV、CX 6/6 100A 1000V 8kV/16A 400V 6kV 无分断能力 固定连接器 I 类 不带联锁
压接连接 -40T125 污染等级3 无负载500 次操作循环 灼热丝850℃ 球压125℃ 针焰 10s PTI175

产品标准和技术要求

CQC1101-2011

认证模式

产品型式试验+初次工厂检查+获证后监督

上述产品符合CQC11-462222-2011认证规则的要求, 特发此证。

发证日期: 2017年02月14日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2016年07月26日

主任: _____

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>



C 0094865



PRODUCT CERTIFICATE

No.: CQC16003149379

NAME AND ADDRESS OF THE APPLICANT

I.L.M.E.SpA
Via Marco Antonio Colonna,9 20149 Milan(MI)-Italy

NAME AND ADDRESS OF THE MANUFACTURER

I.L.M.E.SpA
Via Marco Antonio Colonna,9 20149 Milan(MI)-Italy

NAME AND ADDRESS OF THE FACTORY

I.L.M.E.SpA (V025413)
Via Bovisasca,30-20026 Novate Milanese (MI)-Italy

NAME, MODEL AND SPECIFICATION

Electrical Connectors

CX 02 G 100A 1000V 8kV、CX 6/6 100A 1000V 8kV/16A 400V 6kV 无分断能力 固定连接器 I 类 不带联锁 压接连接 -
40T125 污染等级3 无负载500 次操作循环 灼热丝850℃ 球压125℃ 针焰 10s PT1175

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

CQC1101-2011

CERTIFICATION MODEL

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned products have met the requirements of certification rules
CQC11-462222-2011.

Date of issue: Feb.14,2017

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing
certification body until the expiry date.

Date of original certification: Jul.26,2016

President:


Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0094865



产品认证证书

证书编号: CQC16003149378

申请人名称及地址

I. L. M. E. SpA
Via Marco Antonio Colonna, 9 20149 Milan (MI) - Italy (意大利)

制造商名称及地址

I. L. M. E. SpA
Via Marco Antonio Colonna, 9 20149 Milan (MI) - Italy (意大利)

生产企业名称及地址

I. L. M. E. SpA (V025413)
Via Bovisasca, 30-20026 Novate Milanese (MI) - Italy (意大利)

产品名称和系列、规格、型号

电连接器

CX 01 Y 200A 1000V 8kV IP65, CX 01 YPE 200A 1000V 8kV无分断能力 固定连接器 I 类 不带联锁 压接连接 -40T125 污染等级3
无负载500 次操作循环 灼热丝 850℃ 球压125℃ 针焰10s PTI175

产品标准和技术要求

CQC1101-2011

认证模式

产品型式试验+初次工厂检查+获证后监督

上述产品符合CQC11-462222-2011认证规则的要求, 特发此证。

发证日期: 2016年07月26日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

主任: _____



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C 0086044



PRODUCT CERTIFICATE

No.: CQC16003149378

NAME AND ADDRESS OF THE APPLICANT

I.L.M.E.SpA
Via Marco Antonio Colonna,9 20149 Milan(MI)-Italy

NAME AND ADDRESS OF THE MANUFACTURER

I.L.M.E.SpA
Via Marco Antonio Colonna,9 20149 Milan(MI)-Italy

NAME AND ADDRESS OF THE FACTORY

I.L.M.E.SpA (V025413)
Via Bovisasca,30 20026 Novate Milanese,Milan(MI)-Italy

NAME, MODEL AND SPECIFICATION

Electrical Connectors

CX 01 Y 200A 1000V 8kV IP65、CX 01 YPE 200A 1000V 8kV无分断能力 固定连接器 I类 不带联锁 压接连接 -40T125
污染等级3 无负载500 次操作循环 灼热丝 850℃ 球压125℃ 针焰10s PTI175

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

CQC1101-2011

CERTIFICATION MODEL

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned products have met the requirements of certification rules
CQC11-462222-2011.

Date of issue: Jul.26,2016

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing
certification body until the expiry date.

President:


Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0086044